Fire Test Certificate - Specimen

Fabric: Double Sided Brusan Scenic
Type: M1

J&C Joel
Inspiration in every performance

LABORATOIRE NATIONAL DE MÉTROLOGIE ET D'ESSAIS
LABORATOIRE DE TRAPPES
29 Avenue Roger Hennequin – 78197 Trappes Cedex
Tél : 01 30 69 10 00 – Fax : 01 30 69 12 34

CLASSIFICATION REPORT

Established according to the article 5 of the Department State Order dated 21 November 2002

VALIDITY 5 YEARS from 02 June 2026

N° P259939 - DEC/2

and appendix of 4 pages

Commercial trademark:	Form It Miroir
Bried description:	
Global composition:	Metallised polyester film (0.14 mm – 20 g/m²) laminated (10 g/m²) on aluminium foil (0.08 mm – 216 g/m²)
End-use:	Decoration
Mass:	246 g/m²
Thickness:	0.22 mm
Colour:	Diverse
Test report:	**N° P259939 - DEC/2 dated 02 June 2026**
Type of tests:	Determination of classification according to NF P 92-507 (February 2004) Electrical burner test according to NF P 92-503 (December 1995), cutter cut and draughtproofing

Classification: **M1**

VALID FOR ANY APPLICATION FOR WHICH THE PRODUCT IS NOT SUBJECT TO CE MARKING

Durability of classification (NF P 92-512 : 1986) : A PRIORI UNLIMITED

In view of criteria resulting from the tests described in the appendiced Test Report **N° P259939 - DEC/2**.
To determine the classification, uncertainty on the results has not been taken into account.

The indicated classification prejudges in no way the conformity of the materials commercialized to the samples submitted to the tests and can in no way be considered as a certificate of qualification. This is not a product certification according to the L115-27 article of the consumption code and to the law dated on 3rd June 1994.

Is allowed only the integral reproduction of either this classification report consisting of this unique page, or the whole classification report with the annexed test report consisting of **5 pages**.

Trappes, June 02, 2026

The Head of Fire Behaviour and Fire Safety Department

Thibaut CORNILLON

Traduction du Document P259939 - DEC/1 réalisée par le LNE. La version en langue française fait foi

SPECIMEN

Laboratoire national de métrologie et d'essais • Établissement public à caractère industriel et commercial
Siège social : 1, rue Gaston Boissier 75724 Paris Cedex 15 • Tél. : 01 40 43 37 00 • Fax : 01 40 43 37 37
info@lne.fr • lne.fr • RCS Paris 313 320 244 • NAF : 7120B • TVA : FR 92 313 320 244

United Kingdom
+44 1422 833835
uksales@jcjoel.com

United Arab Emirates
+971 4 884 7801
menasales@jcjoel.com

www.jcjoel.com