Fabric: Gauze (Digital Print)

Type: B1



for the proof of fire behaviour according to DIN 4102-1

Reference: FLT 3630217 (Translation of the German Prüfzeugnis - no guarantee for translation of technical terms)

Order: 2017-07-16 Arrived: 2017-07-17

Description of Uncoated gauze fabric of cotton (GobelinTulle), samples: Independent of the sample of

different colours, type name

(for details see page 2)

Delivered: 2017-07-17

Content of request: Proof of flammability to classify building materials to

class B1 "schwerentflammbar" according to DIN 4102-1

Assessment: The examined product meets the requirements of class B1 for "schwerentflammbare" (not easily flammable) building materials according to DIN 4102-1. If used in

one layer, suspended freely or with distance of >40 mm to the same or other plain materials.

(for details see page 5)

Validity: 2022-08-31

Sampling: The samples were sent to the laboratory by the sponsor

Remark: If the above-mentioned building material is not used as product according to MBO § 2, there is no need for a general building supervisory test certificate.

This test certificate is not valid if the examined building material is used as product in the meaning of state building prescriptions (MBO § 17).

This test certificate does not replace an eventually necessary proof of applicability concerning building supervisory or building laws in the meaning of state building prescriptions. This has to be verified by:

- "allgemeine bauaufsichtliche Zulassung" (general building inspectorate approval) or by
- "allgemeines bauaufsichtliches Prüfzeugnis" (general building inspectorate certificate) or by
- "Zustimmung im Einzelfall" (exceptional approval).

This test certificate can serve as a basis for building supervisory procedures for:

- regulated building products for the pre scribed proofs of conformity
- non-regulated building products for the needed proofs of applicability

Prüfstelle für das Brandverhalten von Baustoffen

Dipl.-Ing. Uwe Kühnast

Steinstrasse 18 D - 14822 Borkheide Fon:+49 33845 90901 Fax:+49 33845 90909 Mail: info@firelabs.de PÜZ-Stelle (LBO): BRA09







This test certificate comprises 5 pages and 5 appendices.

Approved testing, inspection and certification body

This test certificate must not be published and copied preceding agreement of the test laboratory and if agreed, only during validity and unchanged concerning appearance and contents. Agreement of the test laboratory has to be given in any case if norms in which the tests are based or other technical standards have changed.

Fabric: Gauze (Digital Print)

Type: B1



the inspiration behind the performance

Test certificate

page 2 of 5

FLT 3630217

1 Description of test material

1.1 Test material (according to the sponsor)

The delivered materials are flame-retardant treated mesh fabrics made of cotton, printed in black, red and yellow on one side (INFINITUS inkjet printer using colours cyan, magenta, yellow, black). The printed mesh fabrics intended to be used inside of building as advertising space or for decorative purposes and have been designated with the trade name and item number 203 by the client.

1.2 Description of the delivered samples

For the tests, the laboratory received three sections of mesh fabrics, printed in black, red and yellow on one side and on its full surface, each with an approximate length of 3.5 m and a width of 1.5 m, as well as a plain section of the mesh fabric. The delivered samples were not marked and were designated with the trade name by the client.

Colour: white mesh fabric, printed in black, red or yellow on one side Characteristic values: see passage 4.1; photos: see enclosures 1-4 Further details are not known to the laboratory; a retain sample has been deposited.

2 Preparation of samples

For the small burner ("Brennkasten") samples for edge flame exposure (dimensions 190 mm x 90 mm) and samples for surface flame exposure (dimensions 230 mm x 90 mm) were cut in warp and in weft orientation of the mesh fabric.

For the fire shaft ("Brandschacht") tests 8 specimens were assembled. The samples (dimensions 1000 mm x 190 mm) for the test specimens A, C, E and G were cut in warp orientation; the samples for the test specimens B, D, F and H were cut in weft orientation of the mesh fabric.

Afterwards all samples were kept in a climate chamber acc. DIN 50014-23/50-2 until they reached constant weight.

3 Arrangement of samples

The tests in the fire shaft ("Brandschacht") have been performed acc. DIN 4102-1 and -16 (building materials class B1). The small burner tests ("Brennkastenprüfungen") have been performed acc. DIN 4102-1, chapter 6.2.5 (building materials class B2).

Arrangement of the samples: single layer, freely suspended

Period of testing: September 2017

4 Results

section 4.1 Material characteristics

• section 4.2.1 Test results class B2 (small burner test)

• section 4.2.2 Test results class B1 (fire shaft)

4.1 Material characteristics

Table 1

Trade name	Printing ink	Measured values							
		Mass/unit	thickness	Mass/unit	thickness	(m.v.)			
American Mesh 203		[g/m ²]	[mm]	[g/m ²]	[mm]	s			
	without	./.	125	0.75	0.013	100			
	black			0.76	0.016	105			
	red	./.	J.	0.76	0.011	102			
	yellow			0.75	0.012	101			

m.v. mean value s standard deviation

./. not received/not measured



UK Europe Middle East Vietnam Macau Hong Kong

Fabric: Gauze (Digital Print)

B1 Type:



Test certificate page 3 of 5 FLT 3630217

4.2 Results of the fire behaviour

4.2.1 Test results class B2 (Brennkasten)

All building materials class B1 must also meet the requirements of materials of class B2 (flammable). The material, tested in "Brennkasten" acc. DIN 50 050 meets the requirements building materials class B2; the material did not show burning particles/droplets during these tests. Exposing the flame to the front or reverse side did not influence the fire behaviour. (Results: see enclosures 5)

4.2.2 Test results class B1 (Brandschacht)

Table 3

	Test results	"Bran	dscha	chtprü	fung" ((part 1)								
line no		Test results													
		А	В	С	D	E	F	G	Н	require- ments					
1	Number of specimen arrangement acc. DIN 4102 –15 Table 1	1	1	1	1	1	1	1	1						
2	Maximal flame height above bottom edge cm Time 1) min	50 1	50 1	50 1	50 1	50 1	50 1	40 1	40	*)					
4	Burning / melting through Time 1) min	1	1	1	1	1	1	1	1						
5	Back side of the specimens: Flames / glowing Time 1) min:s Discolouring Time 1) min:s	J.	./. ./.	.I. .I.	./. ./.	./.	J.	.1. .1.	.I. .I.						
7 8 9	Falling of burning droplets Begin 1)	No	No	No	No	No	No	No	No						
10 11 12	Falling of burning parts Begin 1)	No	No	No	No	No	No	No	No						
13	Afterflame time at the bottom of the sieve (max.) min:s	. <i>I</i> .	.1.	.J.	J.	./.	./.	.J.	./.						
14	Impairment of the burner flames by dropping or falling Material Time 1) min:s	./.	J.	.I.	.J.	. <i>I</i> .	.J.	J.	./.						
15 16	Premature end of test Final occurrence of burning at the specimen 1) min Time of eventually end of	No 10	No 10	No 10	No 10	No 10	No 10	No 10	No 10	PRI					
	test 1) min:s	./.	./.	.I.	.1.	./.	./.	./.	./.	NEW LEW					

Indication of time: from the beginning of testing procedure

Middle East Vietnam Europe Macau **Hong Kong**

Not tested Not occurred

No cause for complaint

Fabric: Gauze (Digital Print)

Type: B1



Test certificate page 4 of 5 FLT 3630217

	Test results	"Bran	dscha	chtprü	fung"	(part 2	2)				
line						Test	result	S			
no.		Α	В	С	D	Е	F	G	Н	require- ments	
17 18 19 20 21	Afterflame after end of test Time min:s Number of specimen Front side of specimen Back side of specimen Flame length	No									
22 23 24 25 26	Afterglow after end of test Time	No									
27	Back side of specimen Smoke density										
28 29	≤ 400 % min ≥ 400 % min (very strong	0.9	2.7	0.6	1.8	1.9	2.1	4.1	6.9		
30	smoke density) Diagram fig. no.	./. 1	./. 2	./. 5	./. 7	./. 9	./. 11	./. 13	./. 15		
31	Residual length Individual valuecm	50 49 54 53	52 57 55 54	48 53 54 54	47 52 48 49	51 53 54 54	49 58 55 54	62 65 65 63	51 59 52 58	> 0	
32	Average value cm	51	54	52	49	53	54	63	55	≥ 15	
33	Photo of the test specimen fig. no.	2	4	6	8	10	12	14	16		
34 35 36	Flue gas temperature Maximum of average value.°C Time 1) min:s Diagram fig. no.	1	115 10:00 3	5	111 9:56 7	115 9:46 9	9:34 11	112 10:00 13	15	≤ 200	
37	Remarks: line 32: There were no additional tests proceeded because of the residual length of > 45 cm (DIN 4102-16: 2015-09, 5.2 b)). Graphs and photos: see enclosures 1-4.										

indication of time: from the beginning of the test procedure

^{*)} no cause for complaint

A 630217-001 B 630217-002 C 630217-003 D 630217-004 E 630217-005 warp weft warp weft red warp weft warp weft warp weft warp weft warp	
B 630217-002 weft C 630217-003 D 630217-004 red warp weft printed	
D 630217-004 red weft	
D 630217-004 weft	
E 630317 005 warn	
e 030217-003 yellow	- TILL
F 630217-006 yellow weft	PRÜF
G 630217-007 red warp plain >	7"
H 630217-008 red weft	7 1

not tested

^{. /.} not occurred

Fabric: Gauze (Digital Print)

Type: B1



Test certificate page 5 of 5 FLT 3630217

5 Assessment

According to the test results in section 4.2 the material, described in section 1 and 4.1, the tested material fulfils the requirements of a building material class B1 according to DIN 4102-1, if the material is used suspended freely or with a distance of > 40 mm to the same or other plain materials. According DIN 4102-16:2015-09 section 4.2 this assessment is valid for the described fabric and printing process, printed on one side in any colours.

The requirements of building materials class B2 are fulfilled also, no falling of burning parts or droplets occurred during these tests.

The verification for

- outdoor usage (ageing behavior by outdoor weathering) has not been proved.

6 Special remarks

This certificate is only valid for the material as described under paragraph 1. In combination with other materials or with additional coatings or surfaces etc. the burning behaviour may differ

This test certificate is not valid, as soon as the product is used as a building product in the sense of the "Landesbauordnungen" (state building requirements, MBO § 17).

This test certificate is no substitute for a General Building Inspectorate Certificate. This test certificate is granted without prejudice to the rights of third parties, or particular private proprietary rights.

In General Building Inspectorates procedures this test certificate can be based for

- regulated building materials for the required proof of accordance
- for non-regulated building materials for the required proof of applicability

The explanations given in DIN 4102-1 app. D, especially concerning an external production control has to be considered.

This test certificate is valid until 2022-08-31, provided that the test methods, the classification rules and the technology do not change during this period.

Borkheide, 17th of September 2017

Head of the test laboratory (Dipl.-Ing. Uwe Kühnast)

This translation was issued the 14th of October 2017, in a case of doubt the German version is valid solely.

UK Europe Middle East Vietnam Macau Hong Kong


Fabric: Gauze (Digital Print)

Type:



FLT 3630217 enclosure 1 of 5 Test certificate

Test specimen A




Graphs of the flue gas temperature and the smoke density



View of test specimen after the test

Test specimen B



Graphs of the flue gas temperature and the smoke density




Fabric: Gauze (Digital Print)

Type:



FLT 3630217 Test certificate enclosure 2 of 5

Test specimen C



Graphs of the flue gas temperature and the smoke density



View of test specimen after the test

Test specimen D




fig. 7 Graphs of the flue gas temperature and the smoke density



View of test specimen after the test


Fabric: Gauze (Digital Print)

Type:



FLT 3630217 Test certificate enclosure 3 of 5

Test specimen E




Graphs of the flue gas temperature and the smoke density



View of test specimen after the test

Test specimen F



Graphs of the flue gas temperature and the smoke density



Fabric: Gauze (Digital Print)

Type: B1



Test certificate enclosure 4 of 5 FLT 3630217

Test specimen G




fig. 13 Graphs of the flue gas temperature and the smoke density




fig. 14 View of test specimen after the test

Test specimen H




fig. 15
Graphs of the flue gas temperature and the smoke density



View of test specimen after the test

Fabric: Gauze (Digital Print)

Type:



FLT 3630217 Test certificate enclosure 5 of 5

Test results small burner ("Brennkasten") tests

Table 2.1: complete set of samples

(printed red)		W	arp	dire	ectic	n			W	eft/	dim.	require- ments				
Sample-No.	1	2	3	4	5	6	7	1	2	3	4	5	6	7	-	_
Ignition of the sample	1	2	2	2	2	2	2	1	2	2	2	2	2	2	s	-
Maximum flame height	2	3	4	4	4	4	4	3	3	5	4	5	5	4	cm	-
Time of the maximum	3	5	5	4	5	5	5	3	4	5	5	5	5	4	s	-
Flame tip reached the 150 mm mark	./.	./.	./.	./.	./.	./.	./.	./.	./.	./.	./.	.I.	./.	./.	s	≥ 20
Flames extinguished	16	16	16	16	16	16	16	16	16	16	16	16	16	16	s	-
Ignition of filter paper	./.	./.	./.	./.	./.	./.	./.	./.	./.	./.	./.	./.	./.	./.	s	1)
Smoke density (visual)			ve	ry lo	ow					ve		-	=			
Afterburning time	./.	./.	./.	./.	./.	./.	./.	./.	./.	./.	./.	./.	./.	./.	s	-
Flames were extinguished after	./.	./.	J.	./.	./.	./.	./.	./.	./.	./.	./.	./.	./.	./.	S	-

View of the samples after the test (20 seconds after exposure the flame):

The samples were destroyed at flame impingement area up to a max. height of approx. 4 cm and approx. 1,5 cm in width, discoloured above about 4 cm.

Samples 1-5: Edge flame exposure

Surface flame exposure (plain surface) Samples 6: Samples 7: Surface flame exposure (printed surface)

Table 2.2

			prir	itec	l bl	ack				þ	orin	ted	Dim.	Anforde- rungen				
Sample-No.	1	2	3	4	5	6	7	8	1	2	3	4	5	6	7	8	-	-
Ignition of the sample	1	2	2	2	1	2	2	2	1	2	2	2	1	2	2	2	s	-
Maximum flame height	3	3	4	4	2	3	4	3	2	3	4	3	2	3	4	3	cm	-
Time of the maximum	3	3	3	3	3	3	4	3	3	4	5	3	3	5	4	3	s	-
Flame tip reached the 150 mm test mark	./.	./.	./.	./.	./.	./.	./.	./.	./.	./.	./.	./.	./.	./.	./.	./.	s	> 20
Flames extinguished	16	16	16	16	16	16	16	16	16	16	16	16	16	16	16	16	s	s
Ignition of filter paper	./.	./.	./.	./.	./.	./.	./.	./.	./.	J.	./.	./.	./.	./.	./.	.1.	s	1)
Smoke density (visual)	very low										٧	ery		-	-			
Flames have been extinguished	./.	./.	./.	./.	./.	./.	./.	./.	./.	./.	./.	./.	./.	./.	./.	./.	S	-

View of the samples after the test (20 seconds after exposure the flame):

The samples were destroyed at flame impingement area up to a max. height of approx. 4 cm and approx. 1,5 cm in width, discoloured above about 4 cm.

Edge flame exposure, samples in warp direction Samples 1:

Surface flame exposure, samples in warp direction (plain surface)

Samples 3, 4: Surface flame exposure, samples in weft direction (printed surface)

Samples 5: Edge flame exposure, samples in weft direction

Samples 6: Surface flame exposure, samples in warp direction (plain surface) Samples 7, 8: Surface flame exposure, samples in weft direction (printed surface)

No ignition within 20 seconds

Not occurred

dim. Dimension
Indication of time: from the beginning of testing procedure Indication of measurements: from reference line of the flame