Fabric: Joelmat Gloss EN13501-1 Type:





ÖTI – Institut für Ökologie, Technik und Innovation GmbH













Report 66002 Classification Report on Burning Behaviour

Reference

Dr. Laszlo Gottwald

Application

2. extension of the period of validity of the classification 44074.

Test Material

"Unifloor 030/I"

Material used in testing was anonymized for laboratory purposes. A detailed sample list is contained in the report.

Issuing and Signatures

Number of pages contained: 6

Original Issue / Vienna 2011-06-01 / Rm/AM/KK 3149

Authorised for Institute DI (FH) Angelika Hönecke

Technology Ing. Judith Pointner 28

/ pointner@oeti.at



ÖTI – Institut für Ökologie, Technik und Innovation GmbH • Spengergasse 20 • A-1050 Wen • Austria • Tel. +43 1 5442543-0 • Fax +43 1 5442543-10 • Email office@cet.at • Web www.oeti.at • Fint: 326826b • UID-hr ATU65149029 • UniCredit Banik Austria AG • BLZ 12000 • Konto 23410378800 • Iban AT941200023410378800 • Swift BKAUATWW • Eari ATEOS1000015903 • Es gelfen ausschließlich unsere Allgemeinen Geschäftsbedingungen • Only our General Terms and Conditions apply •

Fabric: Joelmat Gloss **Type:** EN13501-1





Report 66002 + 2/6

Contents

1	Order	2
1.1	Chronology	2
1.2	Samples	2
2	Introduction	3
3	Details of classified building product	3
3.1	General	
3.2	Description of the building product	3
4	Test reports and test results for the proof of the classification	
4.1	Test report	3
4.2	Test results - orientating control-test	4
5	Classification and field of application	
5.1	Reference for classification	4
5.2	Classification	4
5.3	Field of application	4
6	Limitations	
6.1	Validity	4
6.2	Notice	5
7	Äquivalenzbeurfeilung zur Verwendung in Österreich	5
8	Remarks	6

1 Order

1.1 Chronology

Date Received Order

2011-04-15 2011-04-20 2. extension of the period of validity of the classification 44074.

1.2 Samples

No. Received Sample Identification
1 2011-04-26 (1) "Unifloor 030/I"

[1] Samples provided by the customer. [2] Sample drawn by ÕTI.

Fabric: Joelmat Gloss **Type:** EN13501-1





Report 66002 + 3/6

2 Introduction

This classification report defines the classification assigned to the building product "Unifloor 030/I" in accordance with the test methods fixed in EN 13501-1.

An orientating control-test of the burning behaviour of the submitted sample was performed. (See pt. 4.2)

3 Details of classified building product

3.1 General

The building product "Unifloor 030/I" is defined as flooring, the classification is valid for the end use application described under point 5.3.

3.2 Description of the building product

Material (of wear layer):	PVC (according to the specification by the applicant)
Construction:	heterogeneous
Kind of wearlayer:	non transparent wear layer
Structure of wearlayer:	smooth floor covering
Colouring:	plain (single coloured)
Dimensions:	rolls
Type of floor covering:	PVC floor covering with foam layer according to EN 651

	specification by ÖTI	specification by the applicant
Total mass	1260 g/m ²	1300 g/m ²
Total thickness	1.8 mm	2.0 mm
Density	agenta e patrauschi e-	1250 kg/m³

The applicant of this classification report guarantees the observance of the instructions of the product specification according to EN 651.

4 Test reports and test results for the proof of the classification

4.1 Test report

Laboratory	ÖTI
Test report number	44074
Date of issue of the classification report	29th July 2003
Test methods	EN ISO 11925-2 and EN ISO 9239-1

Fabric: Joelmat Gloss **Type:** EN13501-1





Report 66002 + 4/6

4.2 Test results - orientating control-test

	Test results	Number of tests
Burning behaviour, EN ISO 9239-1		
Critical radiant flux	≥11 kW/m²	1
Integral of smoke obscuration	95 %.min	1

5 Classification and field of application

5.1 Reference for classification

This classification was carried out within the scope of the classification report 44074 from 29th July 2003 in accordance with EN 13501-1 pt. 11 and 12.2.

5.2 Classification

Due to the results of the orientating control-test which was carried out, the primordially classification of the building product "Unifloor 030/I" is approved.

Burning behaviour	Smoke emission
Cn	sl
Class	ification
C	n-s1

5.3 Field of application

The classification is valid for the building product described in point 3 under the following end use conditions.

Application	Horizontal laid floor covering in form of rolls
Subfloors	Not burnable subfloors of euroclass A1n or A2n with a density of at least 1350 kg/m³.
Installation	glued
Adhesive	Dispersion adhesive Eurocol 643 or similar Note: According to EN13501-1 the stated classification is valid for the tested floor covering together with the tested adhesive, as well as for all other adhesives of the same generic type as the tested adhesive.

6 Limitations

6.1 Validity

Based on the present documents and the results of the performed control-test the validity of the classification report 44074 can be confirmed.

The report stays valid as long as the products are produced in unchanged condition; this is in the responsibility of the manufacturer.

Fabric: Joelmat Gloss **Type:** EN13501-1





Report 66002 + 5/6

6.2 Notice

This classification document does not represent type permission or certifying the product.

If a building product should be CE marked according to system 3 of the attestation of conformity systems, the classification stated with this report is suitable as a basis for the declaration of the producer according to the attestation of conformity system 3, together with a CE marking in the context of the directive relating to construction products.

If the manufacturer plans a CE marking in connection with conformity system 3, he has to give an explanation, which has to be attached to the relevant documents. This explanation confirms, that there are no the specific materials, production processes or procedures (e.g. no additives of flame retarding materials, delimitation of organic components or additions of fillers), which are improfing the burning behaviour to reach the obtained fire classification. As a consequence from this, the manufacturer drew the conclusion that the system 3 of the attestation of conformity systems is appropriate.

The testing laboratory therefore has played no role in the sampling procedure, although the testing laboratory keeps appropriate references from the manufacturer ready, in order to pursue the examined samples,

7 Äquivalenzbeurteilung zur Verwendung in Österreich

Unter Zugrundlegung der Anforderungsbedingungen ist eine eindeutige Zuordnung der ehemaligen österreichischen Brandklassifizierung zu einer europäischen Klasse nicht immer möglich und bedarf umfassender Einstufungserfahrung.

Die vorliegende Äquivalenzbeurteilung soll als Hilfestellung verstanden werden die zeigen soll, in welche europäische Klasse ein Bauprodukt fallen kann, das gemäß österreichischen Normen eingestuft wurde und umgekehrt.

Einstufung gemäß EN 13501-1	Anforderungen aus landesgesetzlichen Bestimmungen	
A1 _{fl}	nichtbrennbar.	
A2 ₁₁ -s1	schwachqualmend	Α
B _{ff} -s1	schwerbrennbar, schwachqualmend	
C _{ff} -s1		B1
D _{ff} -s1	normalbrennbar, schwachqualmend	B2
A2n-s2	normalbrennbar	
B _{ff} -s2		
C _{fl} -s2		
D _{ff} -s2		
En		
F _{fl} 1)	leichtbrennbar	B3

Es wird darauf hingewiesen, dass die Europäische Klasse F auch die Tatsache ausdrücken kann, dass noch gar keine Klassifizierung stattgefunden hat.

Fabric: Joelmat Gloss **Type:** EN13501-1





Report 66002 + 6/6

8 Remarks

Sample Material

Without explicit written other agreement testing is destructive and the sample material is transferred to the property of ÖTI, which is entitled to freely decide on storage and disposal.

Quality management and accreditations

All tests and services are performed under a quality management system according to EN ISO 17025.

ÖTI is accredited by several organisations for various tests offered. It also is a Notified Body for several directives with the registration number 0534 (see http://ec.europa.eu/enterprise/newapproach/nando/). The accreditation by the Federal Ministry of Economy, Family and Youth as testing laboratory was repeated under reference 92.714/0560-1/12/2009 (Individual accredited test procedures are marked with the federal laboratory logo), the accreditation for testing and inspection of construction products was given by the OIB (Austrian Institute of Construction Engeineering). Details and other accreditations are given on request and can be found on www.oetl.at.

Issuance

The valid first issue is done in paper and has single-handed signatures. For reference purposes and filing an unsigned electronic duplicate can be delivered in pdf format. Duplicates and translations will be marked accordingly on the cover sheet.

Copyright und Usage Notes

It is pointed out, that any alterations, amendments or falsifications of reports not authorized by the issuer of the report will be prosecuted as civil and criminal offences; this especially to the appropriate requirements of ABGB, UrhG, UWG and criminal law and their respective international equivalents.

Reports are protected under international copyright laws. Written consent of the ÖTI is required for publications (also in excerpt) and reference to tests for public relation purposes. Reports may only be reproduced in full length.

End of Report