

Fire Test Certificate – Specimen

Fabric: Mirror
Type: BS476

J&C Joel 
the inspiration behind the performance

MATERIAL: 0.20mm Silver Polish FNM 5 F/R

This is to certify that the above material conforms to:

BS476: Part 7: 1971 Surface Spread of Flame.
BS476: Part 6: 1981 Fire Propagation Test.

MATERIAL: 0.20mm Gold 23 Polish FNM 5 F/R

This is to certify that the above material conforms to:

BS476: Part 7: 1987 Surface Spread of Flame.
BS476: Part 6: 1989 Fire Propagation Test.

The materials can be defined as a Class 0 material in accordance with Appendix A, Clause A8 of the Approved Document B2/3/4/to the Building Regulations 1985.

Signed for and on behalf of
Chamberlain Plastics International limited



Technical Manager



Information contained in this publication is to the best of our knowledge accurate at the time of issue and is given in good faith, but we are unable to accept responsibility in respect to factors which are outside our knowledge and control. We assume the user assesses the suitability of the product for their particular application. The data relates only to the specified product and does not relate to use in combination with any other material or in any process.