

# Fire Test Certificate – Specimen

Fabric: Molton Lite  
Type: B1

**J&C Joel**   
Inspiration in every performance

CERTIFIED TRANSLATION FROM GERMAN

1/6

**ibmb MPA**  
TU BRAUNSCHWEIG

Institut für Baustoffe, für das Bauwesen  
Massivbau und Brandschutz

## General Building Authority Test Certificate

Test certificate number: P-3574/850/12-MPA BS

Subject: Fire protection product for cellulose fiber fabrics pursuant to the Construction Products List ("Bauregelliste") A, part 2, version 2011/2, serial number 2.10.2.

Date of issue: May 23, 2017

Date of expiry: July 31, 2022

According to the present General Building Authority Test Certificate, the construction product described above can be used to comply with the State Building Codes ("Landesbauordnungen") of the respective federal state.

The present General Building Authority Test Certificate consists of 6 pages and -- annexes.

The present General Building Authority Test Certificate P-3574/850/12-MPA BS dated May 23, 2017, replaces the General Building Authority Test Certificate no. P-3574/850/12-MPA BS dated July 2, 2012.

The present General Building Authority Test Certificate no. P-3574/850/12-MPA BS was first issued on July 2, 2012.

[ROUND SEAL:] #3  
MPA BRAUNSCHWEIG

The present General Building Authority Test Certificate must only be distributed if it is complete and without any alterations. Excerpts or abridgements need to be authorized by MPA Braunschweig beforehand. Any translations of this document not initiated by MPA must contain the note "Translation of the German original, not verified by Materialprüfanstalt (MPA) für das Bauwesen, Braunschweig". Documents without stamp and signature are not valid. Every page of the present General Building Authority Test Certificate has been stamped with the official seal of MPA Braunschweig.

Materialprüfanstalt (MPA)  
für das Bauwesen  
Beethovenstrasse 52  
D-38106 Braunschweig

Phone +49 (0)531-391-5400  
Fax +49 (0)531-391-5900  
info@mpa.tu-bs.de  
www.mpa.tu-bs.de

Norddeutsche LB Hannover  
106 020 050 Bank code: 250 500 00  
Swift code: NOLADE 2H  
VAT ID: DE183500654  
Tax ID: 14/201/22859  
IBAN: DE58250500000106020050

Notified body (0761-CPD)  
MPA Braunschweig is accredited and notified for testing, supervision, inspection and certification by the building supervision authorities. MPA Braunschweig is accredited as a testing and calibration laboratory in accordance with ISO/IEC 17025 and as an inspection body in accordance with ISO/IEC 17020.



# Fire Test Certificate – Specimen

**Fabric:** Molton Lite  
**Type:** B1

**J&C Joel**   
Inspiration in every performance

## CERTIFIED TRANSLATION FROM GERMAN

2/6

### MPA BRAUNSCHWEIG

Page 2 | General Building Authority Test Certificate no. P-3574/850/12-MPA BS of 05/23/2017



#### I. General provisions

1. The General Building Authority Test Certificate proves that the construction product can be used to comply with the State Building Code ("Landesbauordnung").
2. The General Building Authority Test Certificate does not replace the approvals, permits, authorizations, consents and certifications prescribed by law.
3. The General Building Authority Test Certificate is issued without prejudice to any third party rights, in particular private property rights.
4. Without prejudice to more extensive regulations, the producers and distributors of the construction product must provide the users of the construction product with copies of the General Building Authority Test Certificate and must caution them that the General Building Authority Test Certificate must be available at the site of use. Upon request, the authorities concerned must be provided with copies of the General Building Authority Test Certificate.
5. The present General Building Authority Test Certificate must only be duplicated as a whole. Any extract publication must be authorized by MBA Braunschweig. Texts and drawings in advertising brochures must not contradict the General Building Authority Test Certificate. Translations of the General Building Authority Test Certificate must contain the indication "Translation of the original version not verified by Materialprüfanstalt für das Bauwesen Braunschweig".
6. The General Building Authority Test Certificate is issued until revoked. The General Building Authority Test Certificate can be subsequently amended, especially if new technical achievements require it.


[ROUND SEAL:] #3  
MPA BRAUNSCHWEIG



# Fire Test Certificate – Specimen

Fabric: Molton Lite  
Type: B1

**J&C Joel**   
Inspiration in every performance



# Fire Test Certificate – Specimen

**Fabric:** Molton Lite  
**Type:** B1

**CERTIFIED TRANSLATION FROM GERMAN**

4/6

**MPA BRAUNSCHWEIG**

Page 4 | General Building Authority Test Certificate no. P-3574/850/12-MPA BS of 05/23/2017



**2 Provisions for the construction product**

**2.1 Properties and composition**

- 2.1.1 The fire protection product is a white, crystalline powder and is a combination of different inorganic salts.
- 2.1.2 The composition of \_\_\_\_\_ must correspond to the data stored at the MPA in Braunschweig.

**2.2 Test procedure**

As a fire protection product according to DIN 4102-16, section 7.16.2, the product "KAPPAFLAM CFP", applied on cellulose fiber fabrics, must comply with the requirements for flame-retardant building material (DIN 4102-B1) in accordance with DIN 4102-1<sup>1)</sup>, section 6.1.

**2.3 Basis for issuing the General Building Authority Test Certificate**

Name of the test body	Customer	Number of the Test Certificate/ Date of issue	Test procedure / rules
MPA Braunschweig		3728/336/11-Het of 06/30/2011	DIN 4102-1 : 1998-05 Section 6.1 DIN 4102-16: 1998-05 <sup>2)</sup> Section 7.16.2

**2.4 Production and labeling**

**2.4.1 Production**

For the production of the fire protection product, the provisions of section 2.1 must be complied with.

**2.4.2 Labeling**

The producer must label the construction product, the packaging of the construction product or the package insert – or, if this poses difficulties, the delivery note or an annex to the delivery note - with the Conformity Mark ("Ü-Zeichen") in accordance with the Conformity Mark Ordinances [Übereinstimmungszeichen-Verordnungen] of the federal states. He must only label them if the requirements under section 2.1 and 2.2 have been complied with.

<sup>1)</sup> DIN 4102-1: Fire behavior of building materials and building components: Building materials; concepts, requirements and tests (publication date: May 1998) - Sections 3 and 6.1.

<sup>2)</sup> DIN 4102-16: Fire behavior of building materials and building components: Conducting fire shaft tests (publication date: May 1998) - Sections 7.16.1, 7.16.2, Sections 8 and 9.



[ROUND SEAL:] #3  
 MPA BRAUNSCHWEIG

# Fire Test Certificate – Specimen

Fabric: Molton Lite  
Type: B1

**J&C Joel**   
Inspiration in every performance

## CERTIFIED TRANSLATION FROM GERMAN

### MPA BRAUNSCHWEIG

Page 5 | General Building Authority Test Certificate no. P-3574/850/12-MPA BS of 05/23/2017

**MPA** 5/6  
iBMB TU BRAUNSCHWEIG

The following information must be included on the construction product or the packaging or the package insert or on an annex to the delivery note:

- Product name
- Conformity Mark (“Ü-Zeichen”) with
  - Producer’s name
  - Test Certificate number: P-3574/850/12-MPA BS
  - Logo or name of the certifying body
- Manufacturing site
- Flame-retardant (fire classification DIN 4102-B1) on cellulose fiber fabric
- “Only flame-retardant (fire classification DIN 4102-B1) if a distance of >40 mm is observed to the same or other laminar building materials.

**2.4.3** A note that the resistance to water, dry-cleaning and weathering has not been proved must be integrated into the instructions for use, and a label with the note must be attached to the equipped product.

### 2.5 Proof of conformity (“Übereinstimmungsnachweis”)

#### 2.5.1 General information

The confirmation that the construction product conforms to the regulations of this General Building Authority Test Certificate must be carried out for every production plant with a Certificate of Conformity on the basis of an in-house production control and a regular external supervision - including an initial test of the construction product - in accordance with the following regulations:

To be granted a Certificate of Conformity and for the external supervision including the product tests that need to be carried out, the producer of the construction product must involve an accredited certification body and a supervision board accredited for this.

#### 2.5.2 In-house production control

In every production plant, an in-house production control in accordance with DIN 18200<sup>3)</sup> 2000-05, section 3, must be installed, which ensures the consistent production and composition of the construction product as under section 2.1.

For the in-house production control, the Guidelines Concerning the Proof of Conformity of Flame-Retardant Building Materials (fire classification DIN 4102-B1)<sup>4)</sup> in the applicable version shall apply.

The results of the in-house production control must be recorded, evaluated and retained for at least 5 years. They must be submitted to the supervision board upon request.

#### 2.5.3 External supervision

In every production plant, the in-house production control must be inspected by an external supervision regularly, but at least once a year.

For the external supervision, the Guidelines Concerning the Proof of Conformity of Flame-Retardant Building Materials (fire classification DIN 4102-B1)<sup>4)</sup> in the applicable version shall apply.

[ROUND SEAL:] #3  
MPA BRAUNSCHWEIG

<sup>3)</sup> DIN 18 200 “Proof Conformity for Construction Products - In-house Production Control and Certification of Products” version May 2000 is to be used.

<sup>4)</sup> The „Guidelines Concerning the Proof of Conformity of Flame-Retardant Building Materials (fire classification DIN 4102-B1) after a General Building Authority Approval must be published in the official newsletter of the German Institute for Civil Engineering (“Mitteilungen” des Deutschen Instituts für Bautechnik).

# Fire Test Certificate – Specimen

Fabric: Molton Lite  
Type: B1

**J&C Joel**   
Inspiration in every performance

## CERTIFIED TRANSLATION FROM GERMAN

### MPA BRAUNSCHWEIG

Page 6 | General Building Authority Test Certificate no. P-3574/850/12-MPA BS of 05/23/2017



In the context of the external supervision, an initial testing of the construction product must be carried out. During the external supervision, samples for random inspections must be taken. Sampling and inspection shall be subject to the respective recognized supervision body.

The results of the certification and of the external supervision must be retained for at least five years. They must be submitted by the certification body or the supervision board to the competent supreme building authority upon request.

### 3 Provisions concerning the application

3.1 The fire protection product is applied as an aqueous solution by spraying, submerging and squeezing or spinning on cellulose fiber fabric with a weight per area unit of  $\geq 50$  g/m<sup>2</sup> in a "dry-in-wet" procedure.

At a pick-up of 80 %, a quantity of > 150 g/l of "KAPPAFLAM CFP" is needed on the cellulose fiber fabric to be equipped.

The dry pick-up per weight unit of the fabric must be  $\geq 330$  g/kg.

3.2 The application procedure must be submitted to the user by the applicant in writing in accordance with the test certificate mentioned in section 2.3.

3.3 The fabric equipped with the fire protection product must only be used in closed rooms without any influence of humidity. The persistence of the fire protection equipment against washing, dry-cleaning or weathering has not been proved.

3.4 The proof of the flame-retardant property is only valid for equipped cellulose fiber fabrics arranged with a distance of > 40 mm to laminar building materials.

### 4 Information about legal remedies

Opposition against this decision can be filed within one month after notification with Materialprüfanstalt für das Bauwesen, Braunschweig.

*[Signature]*  
Senior civil servant ["ORR"]  
Dr.-Ing. G. Blume  
Head of test body

[ROUND SEAL:] #3  
MPA BRAUNSCHWEIG

*[Signature]*  
by order: Technical officer  
K. Feustel-Prause  
Official in charge

Braunschweig, May 23, 2017



