

Fire Test Certificate – Specimen

Fabric: Othello
Type: M1

J&C Joel 
Inspiration in every performance



This document is the translation of the French certificate n°18-01300 L on the June, 5th 2018 delivered by IFTH.

MATERIAL REACTION TO FIRE CLASSIFICATION
REPORT PREPARED IN COMPLIANCE WITH AMENDED 5 OF THE FRENCH HOME OFFICE
REGULATION DATED NOVEMBER 21ST, 2002 (OFFICIAL GAZETTE DATED DECEMBER 31, 2002)

Valid five years from issue date

CERTIFICATE N°18-01300 L

And 1 appendice of 6 pages

MATERIAL presented by :

TRADE NAME :

614.013

BRIEF DESCRIPTION :

Velvet 100 % inherent fire resistant polyester
Nominal surface weight : 390 g/m²
Nominal thickness : 2.1 mm
Colours : various

TEST REPORT :

N° 18-01300 E1 - V1 on the June, 5th 2018

TESTS :

Electrical burner test
Flame persistence test
Dripping test.

CLASSIFICATION :


M 1

CLASSIFICATION DURATION (article 5 of appendix 2): unlimited unless otherwise specified

given the criteria resulting from the tests described in the enclosed test report.
The classification indicated does not mean that materials marketed comply with the test samples and must not be considered as a qualification certificate as defined by French law article L.433-3 n°2016-301 dated March 14th, 2016.

N.B.: Only integral copies of this document may be made by photocopying the classification report and/or the classification report and enclosed test report.

Issued in Lyon, France, on the June, 5th 2018



Sophie GUINAMAND
Engineer Tests and Trials



Jean-Marc ORAISON
In charge of Fire Regulation

Siège Social : 14 rue des reculettes – 75013 PARIS ● Tél : +33 (0)1 44 08 19 00 ● Fax : +33 (0)1 44 08 19 39 ● www.ifth.org
SIRET 433 430 832 00108 – NAF 729Z – TVA : FR 39 433430832 – CENTRE TECHNIQUE INDUSTRIEL (LOI DU 22 JUILLET 1948 – ARRETE DU 14 AVRIL 2000)