Fire Test Certificate - Specimen

Fabric: Sprinkler Gauze
Type: EN13501-1

J&C Joel
Inspiration in every performance

PAVUS, a.s.
AUTHORIZED BODY AB 216
NOTIFIED BODY 1391
CERTIFICATION BODY FOR PRODUCT CERTIFICATION No. 3041

V 3041

PAVUS®
FIRE TESTING INSTITUTE

Address:
Prosecká 412/74, 190 00 Prague 9 – Prosek
Phone: 286 019 587, E-mail: mail@pavus.cz
http://www.pavus.cz

Branch:
Fire testing laboratory Veselí nad Lužnicí
Čtvrť J. Hybeše 879, 391 81 Veselí nad Lužnicí
Phone: 381 477 418, E-mail: veseli@pavus.cz

REACTION TO FIRE CLASSIFICATION REPORT

The object of classification:	*Construction products excluding floorings and linear pipe thermal insulation products in accordance with EN 13501-1:2018, clause 11*
Report No:	***PK1-01-26-019-E-0***
Type and product name:	Textile *CO Gitter VDS Art. No. 191 070 *** 303 004*
Issuing organization:	*PAVUS, a.s.* *Accredited certification body for products No 3041* *– Accreditation issued by Czech Accreditation Institute, Public Service Company* *– Certificate of Accreditation No. 272/2026* *Prosecká 412/74* *190 00 PRAHA 9* *Czech Republic* *Order No Z210260073*
Date of issue:	*2026-06-09*
Copies in total:	*2*
Copy number:	*1*
Pages in total:	*4*

SPECIMEN

1 INTRODUCTION

1.1 This classification report defines the classification assigned to *CO Gitter VDS Art. No. 191 070 *** 303 004* in accordance with the procedures given in EN 13501-1:2018.

1.2 This classification report has 4 pages and it can be used or reproduced as a whole only.

2 DETAILED INFORMATION ON THE PRODUCT TO BE CLASSIFIED

2.1 General

The product *CO Gitter VDS Art. No. 191 070 *** 303 004* is made by the company PONGS GROUP GmbH & Co. KG, Bahnhofstraße 21, 07919 Pausa - Mühltroff, Deutschland. It is used free-hanging for cladding of walls and ceilings, digital print, banners, decoration, fairs etc.

2.2 Product description

Thickness:	0.72 mm
Mass per unit area:	90 g/m²
Colour:	white
Composition:	58 % rCO (recycled cotton), 41 % CO (cotton), 1 % recycled mixed fibers

3 REPORTS AND RESULTS IN SUPPORT OF THIS CLASSIFICATION

3.1 Reports

Name of the Laboratory Address Accreditation number:		Report number Date of issue	Test method
PAVUS, a. s. Veselí nad Lužnicí ATL No 1026		*Pr-26-1.104-En 2026-06-09*	*EN 13823:2020+A1:2022*
		Pr-26-1.105-En 2026-06-09	*EN ISO 11925–2:2026*

SPECIMEN

3.2 Results

Test method	Parameter	Number of tests	Results	
			Continuous parameter-mean	Compliance with parameters
EN 13823+A1	*$FIGRA_{0.2\,MJ}$ (W/s)*	3	*0.0*	*≤ 120 (B)*
	THR_{600s} (MJ)		*0.3*	*≤ 7.5 (B)*
	LFS < edge of specimen		*-*	*yes (B)*
	SMOGRA (m^2/s^2)		*0.0*	*≤ 30 (s1)*
	TSP_{600s} (m^2)		*13.6*	*≤ 50 (s1)*
	non-occurring of flaming droplets/particles		*-*	*yes (d0)*
EN ISO 11925 - 2 Surface exposure	*Fs ≤ 150 mm up to 60 s*	6	*-*	*yes (B)*
	Filter paper non-ignition		*-*	*yes (d0)*
EN ISO 11925 - 2 Edge exposure	*Fs ≤ 150 mm up to 60 s*	6	*-*	*yes (B)*
	Filter paper non-ignition		*-*	*yes (d0)*

4 CLASSIFICATION AND FIELD OF APPLICATION

4.1 Classification references

This classification was carried out in conformity with EN 13501-1:2018.

4.2 Classification

The product *CO Gitter VDS Art. No. 191 070 *** 303 004*in relation to its reaction to fire behaviour is classified:

Reaction to fire class: B – s1, d0

4.3 The field of application

This classification is valid for the following product parameters:

Thickness:	0.72 mm
Mass per unit area:	90 g/m²
Colour:	white
Composition:	cannot be changed

This classification applies for the following end-use applications:

Substrate:	free situated product without a substrate or with substrates of reaction to fire classes A1
Way of fixing:	mechanically with fittings of reaction to fire classes A1
Joints:	without joints

SPECIMEN

5 RESTRICTIONS

This classification is valid unless the conditions, under which it was issued, have been changed (i.e., until the materials used, the composition or design of the product or the technical regulations relating to the product change).

The sponsor may request the issuing authority to review the influence of changes on the classification validity.

This classification document does not represent type approval or certification of the product.

Elaborated by:

Ing. Lenka SOBOTOVÁ
Fire testing laboratory

PAVUS, a.s.
Čtvrť J. Hybeše 879
391 81 Veselí nad Lužnicí
IČ: 60193174; DIČ: CZ60193174
(5)

Approved by:

Ing. Jan TRIPES, MBA

AKREDITOVANÝ CERTIFIKAČNÍ ORGÁN PRO CERTIFIKACI VÝROBKŮ č. 3041
PAVUS
FIRE TESTING INSTITUTE
PAVUS, a.s.

SPECIMEN