

Fire Test Certificate - Specimen

Fabric: Wool Serge 565

Type: AS 1530.2

J&C Joel 
Inspiration in every performance

AWTA PRODUCT TESTING

Australian Wool Testing Authority Ltd - trading as AWTA Product Testing
A.B.N 43 006 014 106
1st Floor, 191 Racecourse Road, Flemington, Victoria 3031
P.O Box 240, North Melbourne, Victoria 3051
Phone (03) 9371 2400 Fax (03) 9371 2499

TEST REPORT

Client : J & C Joel Ltd

Corporation Mill, Corporation Street
Sowerby Bridge, Halifax, HX6 2QQ
ENGLAND

Test Number : 18-002989

Issue Date : 6/06/2018

Print Date : 18/06/2018

Sample Description	Clients Ref : "Premier Wool Serge" Milled woven woollen fabric End Use : Curtains & Drapery Nominal Composition : 100% Wool Nominal Mass per Unit Area/Density : 565g/m2 Nominal Thickness : 2.5mm
--------------------	---

AS 1530.2-1993

Methods for Fire Tests on Building Materials, Components and Structures.
Part 2: Test for Flammability of Materials

Date Tested	06/06/2018	
Flammability Index	6	
	Length	Width
Spread Factor	3	5
Heat Factor	1	1
Maximum height (d)		
Mean	4.4	5.4
Coefficient of Variation	18.1	14.8 %
Heat (a)		
Mean	3.3	4.0 °C.min
Coefficient of Variation	18.2	5.0 %
Number of Specimens Tested	6	6
Observation	Melting and visible smoke	

These test results relate only to the behaviour of the test specimens of the material under the particular conditions of the test, and they are not intended to be the sole criterion for assessing the potential fire hazard of the material in use.

132359

28114

Page 1 of 1

© Australian Wool Testing Authority Ltd
Copyright - All Rights Reserved



Accredited for compliance with ISO/IEC 17025 - Testing

- Chemical Testing
- Mechanical Testing
- Performance & Approvals Testing


: Accreditation No. 983
: Accreditation No. 985
: Accreditation No. 1356



Samples and their identifying descriptions have been provided by the client unless otherwise stated. AWTA Ltd makes no warranty, implied or otherwise, as to the source of the tested samples. The above test results relate only to the sample or samples tested. This document shall not be reproduced except in full and shall be rendered void if amended or altered. This document, the names AWTA Product Testing and AWTA Ltd may be used in advertising providing the content and format of the advertisement have been approved by the Managing Director of AWTA Ltd.


0204/11/06

MICHAEL A. JACKSON B.Sc.(Hons)
MANAGING DIRECTOR



+44 1422 833835

uksales@jcjoel.com



+971 4 884 7801

menasales@jcjoel.com

www.jcjoel.com