Fire Test Certificate - Specimen

Fabric: Pure Velvet
Type: M1

J&C Joel
Inspiration in every performance

Institut Français du Textile et de l'Habillement

This document is the translation of the French certificate n° 22-01452 L delivered by IFTH on the June 3th 2022

MATERIAL REACTION TO FIRE CLASSIFICATION REPORT
PREPARED IN COMPLIANCE WITH AMENDED 5 OF THE FRENCH HOME OFFICE REGULATION
REGULATION DATED NOVEMBER 21ST, 2002 (OFFICIAL GAZETTE DATED DECEMBER 31, 2002)

Valid five years from issue date

CERTIFICATE N° 22-01452 L

And 1 Appendix of 6 pages

TRADE NAME:	7610 PURE
BRIEF DESCRIPTION:	100% inherent flame retardant polyester fabric Nominal surface weight : 420 g/m² +/-5% Nominal thickness : 2.3 mm +/-5% Colours : Black
TEST REPORT :	N° 22-01452 E1V1 on the June 3th 2022
TESTS :	Electrical burner test Flame persistence test Dripping test

SPECIMEN

CLASSIFICATION **M1**

Classification valid for any application for which the product is not subjected to the CE marking of the Construction products

CLASSIFICATION DURATION (article 5 of appendix 2) : unlimited unless otherwise specified

given the criteria resulting from the tests described in the enclosed test report.
The classification indicated does not mean that materials marketed comply with the test samples and must not be considered as a qualification certificate as defined by French law dated March 14, 2016.

N.B.: Only integral copies of this document may be made by photocopying the classification report and/or the classification report and enclosed test report.

Issued in Lyon, France, on the June 3th 2022

Olivier PALLAS
Tests and Trials Engineer

Siège Social : 14 rue des reculettes – 75013 PARIS Tél : +33 (0)1 44 08 19 00 Fax :+33 (0)1 44 08 19 39 www.ifth.org
SIRET 433 430 832 00108 – NAF 729Z – TVA : FR 39 433430832 – CENTRE TECHNIQUE INDUSTRIEL (LOI DU 22 JUILLET 1948 – ARRETE DU 14 AVRIL 2000)

United Kingdom
+44 1422 833835
uksales@jcjoel.com

United Arab Emirates
+971 4 884 7801
menasales@jcjoel.com

www.jcjoel.com