

Fire Test Certificate

Fabric: Novello Crushed Velvet

Type: NFPA 701

J&C Joel 
Inspiration in every performance



(28115) 21, Yangcheong-3gil, Ochang-eup, Cheongwon-gu, Chungbuk, Korea
Tel : 043-711-8705 Fax : 043-711-8741

TEST REPORT



APPLICANT : J&C JOEL Ltd.

REPORT NO. : M270-26-03865

SAMPLE RECEIVED DATE : 2026-07-16

REPORT ISSUED DATE : 2026-07-27

PAGE : 1 OF 2

SAMPLE DESCRIPTION : ONE(1) sample

SAMPLE NAME SUBMITTED BY THE APPLICANT : IFR Crushed Velvet

TEST CONDUCTED : As requested by the applicant, for details please see attached page(s).

SPECIMEN

PREPARED AND CHECKED BY
FOR FITI

Jeong-kyun Ju

JEONG-KYUN JU
QUALITY MANAGER

AUTHORIZED BY
FOR FITI

YUN JU KEYNG

JU-KEYNG YUN
PRESIDENT

✽ Report Verification No.: BNKI-H19L-UV03 ✽

(You can see the authenticity of your test report through the above "Report Verification No." at FITI homepage.)

e-DOCUMENT SERVICE

The test results contained in this report are limited to results on the sample(s) that is provided by client and are not necessarily indicative or representative of the quality of the lot from which the sample(s) was taken or of all products. Results contained in this report are not based on the quality certification of sample by the FITI quality certification program unless specifically requested by the client. Further use of the results of this report is prohibited unless allowed under a separate agreement set forth in an official document that is established between the client identified on this letter and the FITI.

This test report is irrelevant to KS Q ISO/IEC 17025 and KOLAS accreditation.
Only the original report (including reissue) is valid. The test report received via e-mail (including its copy and the file) is an e-document for reference of test results and is NOT the official Document.



United Kingdom



+44 1422 833835



uksales@jcjoel.com



United Arab Emirates



+971 4 884 7801



menasales@jcjoel.com

www.jcjoel.com

Fire Test Certificate

Fabric: Novello Crushed Velvet

Type: NFPA 701

J&C Joel
Inspiration in every performance



(28115) 21, Yangcheong-3gil, Ochang-eup, Cheongwon-gu, Chungbuk, Korea

Tel : 043-711-8705 Fax : 043-711-8741

REPORT NO.: M270-26-03865

PAGE : 2 OF 2

01. FLAMMABILITY (NFPA 701 : 2023, TEST METHOD 1)

#1					
Sample No.	Mass(g)		Mass loss(%)	After flame time(s)	Drip burn(s)
	Original	After test			
1	20.6	16.5	19.9	0	0
2	20.7	15.6	24.6	0	0
3	20.6	16.0	22.3	0	0
4	20.6	16.3	20.9	0	0
5	20.6	15.9	22.8	0	0
6	20.6	15.7	23.8	0	0
7	20.6	16.2	21.4	0	0
8	20.7	15.8	23.7	0	0
9	20.7	16.0	22.7	0	0
10	20.6	16.3	20.9	0	0
Avg.	20.6	16.0	22.3	0	0
Conclusion	Based upon the results of the test report, the submitted sample meets performance requirements as stated in NFPA 701:2023 TEST METHOD 1				

NOTE) Requirement

Drip burn(s)	Mass loss(%)	No individual specimen's mass loss exceed the mean value plus 3 standard.
Avg. : less than 2	Avg. : less than 40	Ø Standard deviation = 1.52 The mean value plus 3 standard = 26.8

Tests were conducted only in the original state by the client's request

**** End of The Report ****



e-DOCUMENT SERVICE

The test results contained in this report are limited to results on the sample(s) that is provided by client and are not necessarily indicative or representative of the qualities of the lot from which the sample(s) was taken or of all products. Results contained in this report are not based on the quality certification of sample by the FITI quality certification program unless specifically requested by the client. Further use of the results of this report is prohibited unless allowed under a separate agreement set forth in an official document that is established between the client identified on this letter and the FITI. This test report is Irrelevant to KS Q ISO/IEC 17025 and KOLAS accreditation. Only the original report (including reissue) is valid. The test report received via e-mail (including its copy and the file) is an e-document for reference of test results and is NOT the official Document.



United Kingdom



+44 1422 833835



uksales@jcjoel.com



United Arab Emirates



+971 4 884 7801



menasales@jcjoel.com

www.jcjoel.com